

LOAN DOCUMENT

PHOTOGRAPH THIS SHEET

DTIC ACCESSION NUMBER

LEVEL

INVENTORY

WL-TR-96-2089

DOCUMENT IDENTIFICATION

DISTRIBUTION STATEMENT A

Approved for public release
Distribution Unlimited

DISTRIBUTION STATEMENT

ACCESSION FOR	
NTIS	GRAM
DTIC	TRAC
UNANNOUNCED	
JUSTIFICATION	
BY	
DISTRIBUTION/	
AVAILABILITY CODES	
DISTRIBUTION	AVAILABILITY AND/OR SPECIAL
A-1	

DISTRIBUTION STAMP

DTIC QUALITY INSPECTED 1

A-1 19960812 158

DATE RECEIVED IN DTIC

DATE ACCESSIONED

DATE RETURNED

REGISTERED OR CERTIFIED NUMBER

PHOTOGRAPH THIS SHEET AND RETURN TO DTIC-FDAC

H
A
N
D
L
E

W
I
T
H

C
A
R
E

WL-TR-96-2089

**FILM COOLING HEAT TRANSFER WITH
HIGH FREE STREAM TURBULENCE**



**John J. Schauer
David J. Pestian**

November 17-22, 1995

FINAL REPORT 1 NOVEMBER 1995--9 JULY 1996

Approved for public release; distribution unlimited

**AERO PROPULSION & POWER DIRECTORATE
WRIGHT LABORATORY
AIR FORCE MATERIEL COMMAND
WRIGHT-PATTERSON AIR FORCE BASE, OH 45433-7650**

This paper is declared a work of the U.S. Government and as such is not subject to copyright protection in the United States

NOTICE

WHEN GOVERNMENT DRAWINGS, SPECIFICATIONS, OR OTHER DATA ARE USED FOR ANY PURPOSE OTHER THAN IN CONNECTION WITH A DEFINITELY GOVERNMENT-RELATED PROCUREMENT, THE UNITED STATES GOVERNMENT INCURS NO RESPONSIBILITY OR ANY OBLIGATION WHATSOEVER. THE FACT THAT THE GOVERNMENT MAY HAVE FORMULATED OR IN ANY WAY SUPPLIED THE SAID DRAWINGS, SPECIFICATIONS, OR OTHER DATA, IS NOT TO BE REGARDED BY IMPLICATION, OR OTHERWISE IN ANY MANNER CONSTRUED, AS LICENSING THE HOLDER, OR ANY OTHER PERSON OR CORPORATION; OR AS CONVEYING ANY RIGHTS OR PERMISSION TO MANUFACTURE, USE, OR SELL ANY PATENTED INVENTION THAT MAY IN ANY WAY BE RELATED THERETO.

THIS REPORT IS RELEASABLE TO THE NATIONAL TECHNICAL INFORMATION SERVICE (NTIS). AT NTIS, IT WILL BE AVAILABLE TO THE GENERAL PUBLIC, INCLUDING FOREIGN NATIONS.


THE TECHNICAL REPORT HAS BEEN REVIEWED AND IS APPROVED FOR PUBLICATION.



RICHARD B. RIVIR
Manager, Aerothermal Research
Turbine Branch
Turbine Engine Division
Aero Propulsion & Power Directorate



CHARLES D. MACARTHUR
Chief
Turbine Branch
Turbine Engine Division
Aero Propulsion & Power Directorate



RICHARD J. HILL
Chief of Technology
Turbine Engine Division
Aero Propulsion & Power Directorate

IF YOUR ADDRESS HAS CHANGED, IF YOU WISH TO BE REMOVED FROM OUR MAILING LIST, OR IF THE ADDRESSEE IS NO LONGER EMPLOYED BY YOUR ORGANIZATION PLEASE NOTIFY WL/POTT, WPAFB OH 45433-7650 TO HELP MAINTAIN A CURRENT MAILING LIST.

REPORT DOCUMENTATION PAGE			Form Approved OMB No. 0704-0188	
Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.				
1. AGENCY USE ONLY (Leave blank)	2. REPORT DATE November 17-22, 1995	3. REPORT TYPE AND DATES COVERED Final 1 Nov 95 - 9 Jul 96		
4. TITLE AND SUBTITLE Film Cooling Heat Transfer with High Free Stream Turbulence		5. FUNDING NUMBERS PE 61102F JON 2307S315		
6. AUTHOR(S) John J. Schauer, David J. Pestian				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) Aero Propulsion & Power Directorate Wright Laboratory Air Force Materiel Command Wright-Patterson Air Force Base, OH 45433-7650		8. PERFORMING ORGANIZATION REPORT NUMBER		
9. SPONSORING / MONITORING AGENCY NAME(S) AND ADDRESS(ES) Aero Propulsion & Power Directorate Wright Laboratory Air Force Materiel Command Wright-Patterson Air Force Base, OH 45433-7650 POC: Richard B Rivir, WL/POTT, 513-255-5132		10. SPONSORING / MONITORING AGENCY REPORT NUMBER WL-TR-96-2089		
11. SUPPLEMENTARY NOTES				
12a. DISTRIBUTION / AVAILABILITY STATEMENT APPROVED FOR PUBLIC RELEASE; DISTRIBUTION IS UNLIMITED			12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) Heat transfer coefficients are shown as functions of downstream and transverse plate coordinates as determined experimentally for different blowing ratios near one and for levels of free stream turbulence from 1 percent to 17 percent of the free stream velocity. Heat transfer between the plate and the free stream is reduced by the film cooling at higher levels of free stream turbulence. Heat transfer is increased on the plate in the region between the film cooling jets at all levels of blowing ratio for one percent free stream turbulence. This undesirable augmentation of the heat transfer is modeled analytically and related to the axial vortices generated near the film cooling jet inlets. The strength of these vortices and the subsequent heat transfer increases are related to the blowing ratio.				
14. SUBJECT TERMS			15. NUMBER OF PAGES 11	
			16. PRICE CODE	
17. SECURITY CLASSIFICATION OF REPORT UNCLASSIFIED	18. SECURITY CLASSIFICATION OF THIS PAGE UNCLASSIFIED	19. SECURITY CLASSIFICATION OF ABSTRACT UNCLASSIFIED	20. LIMITATION OF ABSTRACT SAR	

GENERAL INSTRUCTIONS FOR COMPLETING SF 298

The Report Documentation Page (RDP) is used in announcing and cataloging reports. It is important that this information be consistent with the rest of the report, particularly the cover and title page. Instructions for filling in each block of the form follow. It is important to ***stay within the lines*** to meet ***optical scanning requirements***.

Block 1. Agency Use Only (Leave blank).

Block 2. Report Date. Full publication date including day, month, and year, if available (e.g. 1 Jan 88). Must cite at least the year.

Block 3. Type of Report and Dates Covered. State whether report is interim, final, etc. If applicable, enter inclusive report dates (e.g. 10 Jun 87 - 30 Jun 88).

Block 4. Title and Subtitle. A title is taken from the part of the report that provides the most meaningful and complete information. When a report is prepared in more than one volume, repeat the primary title, add volume number, and include subtitle for the specific volume. On classified documents enter the title classification in parentheses.

Block 5. Funding Numbers. To include contract and grant numbers; may include program element number(s), project number(s), task number(s), and work unit number(s). Use the following labels:

C - Contract	PR - Project
G - Grant	TA - Task
PE - Program Element	WU - Work Unit Accession No.

Block 6. Author(s). Name(s) of person(s) responsible for writing the report, performing the research, or credited with the content of the report. If editor or compiler, this should follow the name(s).

Block 7. Performing Organization Name(s) and Address(es). Self-explanatory.

Block 8. Performing Organization Report Number. Enter the unique alphanumeric report number(s) assigned by the organization performing the report.

Block 9. Sponsoring/Monitoring Agency Name(s) and Address(es). Self-explanatory.

Block 10. Sponsoring/Monitoring Agency Report Number. (If known)

Block 11. Supplementary Notes. Enter information not included elsewhere such as: Prepared in cooperation with...; Trans. of...; To be published in.... When a report is revised, include a statement whether the new report supersedes or supplements the older report.

Block 12a. Distribution/Availability Statement. Denotes public availability or limitations. Cite any availability to the public. Enter additional limitations or special markings in all capitals (e.g. NOFORN, REL, ITAR).

DOD - See DoDD 5230.24, "Distribution Statements on Technical Documents."

DOE - See authorities.

NASA - See Handbook NHB 2200.2.

NTIS - Leave blank.

Block 12b. Distribution Code.

DOD - Leave blank.

DOE - Enter DOE distribution categories from the Standard Distribution for Unclassified Scientific and Technical Reports.

NASA - Leave blank.

NTIS - Leave blank.

Block 13. Abstract. Include a brief (*Maximum 200 words*) factual summary of the most significant information contained in the report.

Block 14. Subject Terms. Keywords or phrases identifying major subjects in the report.

Block 15. Number of Pages. Enter the total number of pages.

Block 16. Price Code. Enter appropriate price code (*NTIS only*).

Blocks 17. - 19. Security Classifications. Self-explanatory. Enter U.S. Security Classification in accordance with U.S. Security Regulations (i.e., UNCLASSIFIED). If form contains classified information, stamp classification on the top and bottom of the page.

Block 20. Limitation of Abstract. This block must be completed to assign a limitation to the abstract. Enter either UL (unlimited) or SAR (same as report). An entry in this block is necessary if the abstract is to be limited. If blank, the abstract is assumed to be unlimited.

FILM COOLING HEAT TRANSFER WITH HIGH FREE STREAM TURBULENCE

John. J. Schauer
Professor
University of Dayton
Dayton, OH 45469-0210

David. J. Pestian
Assistant Research Engineer
University of Dayton Research Institute
Dayton, OH 45469-0140

ABSTRACT

Heat transfer coefficients are shown as functions of downstream and transverse plate coordinates as determined experimentally for different blowing ratios near one and for levels of free stream turbulence from 1 percent to 17 percent of the free stream velocity. Heat transfer between the plate and the free stream is reduced by the film cooling at higher levels of free stream turbulence. Heat transfer is increased on the plate in the region between the film cooling jets at all levels of blowing ratio for one percent free stream turbulence. This undesirable augmentation of the heat transfer is modeled analytically and related to the axial vortices generated near the film cooling jet inlets. The strength of these vortices and the subsequent heat transfer increases are related to the blowing ratio.

Nomenclature

A_s	side area under the cooling flow (m^2)
d	film cooling hole diameter (1.9cm)
M	blowing ratio ($\rho_{fc} U_{fc} / \rho_{fs} U_{fs}$)
T	static temperature (deg. K)
T^*	local temperature difference from free stream value (deg. K)
T_m	difference between maximum temperature on a constant x/d plane and the associated free stream value (deg. K)
Tu	turbulence intensity (u'/u) (%)
c	gas specific heat at constant pressure (J/kg deg. K)
h	convection coefficient, $q''/(T_w - T_{fs})$ (W/m^2K)
h_{aw}	convection coefficient, $q''/(T_{aw} - T_{fs})$ (W/m^2K)
k	empirical constant in equation (2)
q''	local heat flux (W/m^2)
r	radial distance from center of axisymmetric coolant jet (m)
u	mean local stream wise velocity (m/s)
u'	fluctuating stream wise velocity component (m/s)
v	mean local vertical velocity (m/s)
w	mean local transverse velocity (m/s)
W	velocity related to the vortex strength (m/s)
x	stream wise dist. from downstream lip of injection hole (m)
y	vertical distance from injection surface (m)
z	span wise distance from centerline of injection hole (m)
δ	boundary layer thickness (m)
ρ	fluid density (kg/m^3)
γ	angle between cooling jet and the plate (radians)

Subscripts:

aw	evaluated at $y=0$ (wall value), with $q''=0$
fc	in the film cooling fluid
fs	in the free stream fluid
nofc	no film cooling
std	standard
w	evaluated at $y=0$ (wall value)

INTRODUCTION

Turbine blades in modern aircraft operate with the flow over them hot enough to melt the blades. Cooling is a necessity and the cooling flow can at most reach the blade temperature. Since the cooling flow is cooler than the main flow, it is available for film cooling after it has completed the blade cooling function. This experimental and analytical study shows the cooling potential at blowing ratios near one and at levels of Free Stream Turbulence (FST) up to 17 percent. The analytical study focuses particularly on the conditions where heat transfer is augmented rather than having the desirable heat transfer reducing effect.

This study utilizes the apparatus configured by Bons et al. (1994) and also used in the jet mixing study of Schauer and Bons (1994). Experimental data were collected with flow parameters in the range of typical turbine applications. The Reynolds number based on film cooling hole diameter was 20,000 and the blowing ratios were near one. The data presented corresponds to x/d from 0 to 60. The density ratio between the cooling flow and the main stream was approximately 0.93.

EXPERIMENTAL FACILITY

The wind tunnel used for the experiments has a 0.38m (width) by 0.18m (height) cross-section. An elliptical-edge bleed with vacuum suction is located 12.07cm upstream of the downstream lip of the film cooling injection hole (designated as $x/d = 0$). A 1.59mm diameter steel rod located 2.54cm from the elliptical-edge bleed is used to trip the new boundary layer and insure a span wise uniform turbulent boundary layer profile at the injection point. Without employing turbulence generating devices, the tunnel's free stream turbulence level is 0.9% (± 0.05) and velocity uniformity is within $\pm 2.5\%$. Free stream turbulence generation is accomplished by two methods for the present experimental data. A secondary flow is injected from two opposing rows of holes located on the top and

bottom of the wind tunnel 1.02m upstream of the boundary layer bleed at a velocity ratio (jet to free stream velocity) of 14 to produce a turbulence level of 17% (± 0.85) at the film cooling injection station. To provide a turbulence level of 6.5% (± 0.3), a standard square grid is installed 0.94m upstream of the coolant injection point. The film cooling is injected through a 1.9cm diameter, 35 degree inclined hole centered in the test section. The injection pipe length from the coolant access plenum to the exit is 3.5 hole diameters. A diagram of this experimental configuration is shown in Schauer and Bons (2).

The data presented in this report were taken using a 4 μ m diameter tungsten hot wire. The hot wire and a flow temperature thermocouple (0.33mm bead diameter) are mounted on a vertical traverse. A velocity map of the injection plane (x-z plane at $y = 0$) was used to calibrate an orifice plate used to determine the film cooling flow rate. This flow rate and the local free stream density-velocity product are used to calculate the film cooling blowing ratio. The test surface downstream of the film cooling injection point is a constant heat flux film over a 10 cm layer of urethane foam. Heat transfer coefficients are based on the known heat flux per unit area and the temperature difference between the free stream and the local wall temperature as measured by axially spaced thermocouples in the plate. The cooling holes were moved sideways relatively to the plate to permit heat transfer coefficients to be determined as functions of both axial and transverse positions. Uncertainty in the heat transfer coefficients is estimated at $\pm 4\%$ but the relative values are much more accurate. Uncertainty in the velocity measurement, estimated at $\pm 2.0\%$, is attributed to the calibration fit accuracy and the horizontal displacement between the probe and the flow thermocouple. The uncertainty in the temperature ratio data is $\pm 0.7\%$.

ANALYTICAL DEVELOPMENT

At a blowing ratio near one, the cooling flow spreads and mixes slowly in the transverse direction at low levels of FST. Under these circumstances the axial vortex generated by the main stream flow sweeping under the cooling jet flow near the jet exit causes significant changes in the boundary layer where the vortex pair meet midway between holes.

The vortex strength is analyzed using the moment of momentum control volume approach from Shapiro (1953) Eq. (1.17) applied to the control volume $L \times L \times L$ shown in Fig. 1.




Figure 1. Control Volume for Vorticity Analysis

As shown in Fig. 1, L is the distance from the hole centerline to the midpoint between holes, in this case $1.5 d = L$. The transverse component of the force on this control volume is associated with the reduced pressure under the cooling jet. This force was computed as

$$F = \int \Delta P dA_s \quad (1)$$

where A_s is the area between the jet centerline and the plate and ΔP is the difference between the pressure in the main stream and the average pressure under the jet. This pressure difference was taken to be

$$\Delta P = 1/2 k \rho u_b^2 \gamma \quad (2)$$

Here the combined effect of A_s , k , and γ are functions of the blowing ratio determined empirically. These empirical values will effect W_2 from Eq. 10, which is chosen based on the heat transfer data.

With the approximation that the force in the z direction given by Eq. (1) is located near the plate since the pressure differential is under the cooling flow, the lever arm about the top of the control volume (axis $z = 0$, $y = L$, extending in the x direction) is L . Then moment of momentum equation reduces to

$$LF = \rho u_{fs} L^2 (V \times r)_{out} \quad (3)$$

Shapiro (1953) relates angular velocity (page 270) to this moment of momentum, giving

$$2 \omega L^2 = (V \times r)_{out} \quad (4)$$

Estimating the velocity at the edge of the vortex, W , as the angular velocity ω times L and combining the above equations gives

$$W = L \omega = A_s k u_b^2 / 4 L^2 \quad (5)$$

In order to analyze heat transfer, the boundary layer development is investigated with the velocity corresponding to the vortex considered. The ratio of heat transfer coefficient with angular velocity to the heat transfer without (standard flat plate) is predicted.

Boundary layer growth at the midline between holes is examined using the control volume shown in Fig. 2. Notice that this control volume has a downward velocity $v(\delta)$ coming uniformly in the top and also the same velocity W coming out one side. The other side is on the midline and has no mean z component of velocity from symmetry.




Figure 2. Control Volume for Boundary Layer Growth Near Midline

The law of conservation of mass for this control volume results in

$$\frac{L}{4} \frac{d}{dx} \int_0^{\delta} u dy + W \int_0^{\delta} dy - \frac{L}{4} v(\delta) = 0 \quad (6)$$

The W in the second term of Eq. 6 represents the z component of velocity assumed constant from $y = 0$ to δ . The $v(\delta)$ in the third term is the vertical downward velocity component. Applying control volume x momentum to the same control volume and assuming no pressure changes in the x direction gives

$$-\frac{\tau_w}{\rho} \frac{L}{4} = \frac{L}{4} \frac{d}{dx} \int_0^{\delta} u^2 dy - u_{fs} v(\delta) \frac{L}{4} + W \int_0^{\delta} u dy \quad (7)$$

Eliminating $v(\delta)$ between Eq. (6) and Eq. (7) relating the wall shear to δ via the Blasius relationship Eq. (10-18) of Kays and Crawford (1980) gives

$$\begin{aligned} -0.0225 u_{fs}^2 \left(\delta u_{fs} / \nu \right)^{-1/4} \frac{L}{4} &= \frac{L}{4} u_{fs}^2 \frac{d\delta}{dx} \int_0^1 \left(\frac{u}{u_{fs}} \right)^2 d\left(\frac{y}{\delta} \right) - \\ &u_{fs} W \delta - \frac{L}{4} u_{fs} \frac{d\delta}{dx} \int_0^1 \frac{u}{u_{fs}} d\left(\frac{y}{\delta} \right) + u_{fs}^2 \delta \frac{W}{u_{fs}} \int_0^1 \frac{u}{u_{fs}} d\left(\frac{y}{\delta} \right) \end{aligned} \quad (8)$$

With the usual one seventh power profile, $u/u_{fs} = (y/\delta)^{1/7}$ we get

$$\frac{d\delta}{dx} + \frac{36}{7} \frac{W}{u_{fs}} \frac{\delta}{L} = 0.231 \left(\frac{u_{fs}}{\nu} \right)^{-1/4} \delta^{-1/4} \quad (9)$$

With the substitution $\Delta = \delta^{5/4}$ and the boundary condition $\delta = 0$ at $x = 0$ the solution becomes, for W constant

$$\Delta = \frac{bL}{w} (1 - e^{-c\eta}) \quad (10)$$

where

$$c = 45 W u_{fs}/7 \text{ and } \eta = x/L$$

in the limit as W approaches zero the standard flat plate boundary layer solution follows from Eq. (10) as $\Delta_{std} = bx$. Notice that for constant W the boundary layer thickness approaches a constant value as x gets large.

We have generated a solution for the boundary layer thickness and via the Blasius relationship, the wall shear. Further, the heat transfer at a point is proportional to the wall shear stress. Our solution, however, assumes that the vorticity is constant as generated in the first $x = L$ past the hole centerlines. While this could be valid if shear were neglected, our solution is applied at the plate where wall shear opposes the motion and reduces the vortex strength. The spreading of the vortex vertically as it goes downstream would also reduce the velocities associated with it.

In order to maintain mathematical simplicity and with hints from the measured data, we will assume for x/L greater than 2

$$W / u_{fs} = W_2 / (u_{fs} (1 + (\eta - 2))) \quad (11)$$

This function decays from $W/W_2 = 1$ at $x/L = 2$ to a ratio of 1 to 60 at x/L of 61 effectively reducing W to near zero at large x/L values. W_2 is determined from Eq. (9) at x/L of 2. The solution of Eq. (8) with Eq. (10) for W is

$$\frac{\Delta}{\Delta_{std}} = \left(\frac{D - D^{-w}}{1 + w} + \frac{1 - e^{-2w}}{w} D^{-w} \right) \quad (12)$$

where

$$D = (1 + (\eta - 2)), \quad \text{the denominator of Eq. (11).}$$

At the midline, the ratio of heat transfer with no film cooling to the heat transfer with dominance of an axial vortex (dominance only with low FST values) is

$$h/h_{nofc} = (\Delta/\Delta_{std})^{-1/5} \quad (13)$$

This result used with Eq. (12) is compared to the measured heat transfer data to get a vorticity velocity W_2 at various blowing ratios. This is essentially picking A_s , k , and γ as functions of blowing ratio. The empirically selected values are

M	W_2
0.7	0.10
1.0	0.18
1.5	0.21

Table 1. Empirical Input Based on Heat Transfer

RESULTS




Figure 3. No Film Cooling Heat Transfer Coefficient

Heat transfer coefficients are presented in Fig. 3 for no film cooling flow but three levels of FST. We see that there is a clear effect of FST with h increasing with increasing FST levels. It was also observed, but not shown here, there was virtually no effect of z location. The low FST data was within a few percent of standard results. These data are the base or standard heat transfer coefficients that are the comparison basis for the film cooling cases.




Figure 4a. Film Cooling Heat Transfer with 1% FST, $M = 0.7$

The low FST with film cooling heat transfer coefficients are shown in Fig. 4. at the limiting blowing ratios. The film cooling flow with a temperature between the free stream temperature and the plate temperature is designed to lower the h from the flat plate conditions shown in Fig. 3. We see that it is not only ineffective but that it raises the h at z locations near the midline for all axial locations. This heat transfer augmentation is predicted by the analytical development. This effect has long been recognized as shown in Jones and Forth (1986).




Figure 4b. Film Cooling Heat Transfer with 1% FST, $M = 1.5$

Figure 5 shows the same data reduced with the addition of effectiveness data both published and unpublished from the work of Bons et al. (1994). This heat transfer coefficient based on temperature difference from adiabatic wall conditions shows increased h on the midline between the holes at $x/d > 10$ for low FST.




Figure 5a. Adiabatic Wall Heat Transfer with 1% FST, $M = 0.7$




Figure 5b. Adiabatic Wall Heat Transfer with 1% FST, $M = 1.5$

Seventeen percent FST with film cooling heat transfer coefficients are shown in Fig. 6. Here the film cooling is doing the job it is designed to do, that is reduce the heat transfer coefficient. Some influence of the axial vortices is seen at x/d of 10 but the augmentation disappears as the cooling film spreads in the z direction with increasing x .




Figure 6a. Film Cooling Heat Transfer with 17% FST, $M = 0.7$




Figure 6b. Film Cooling Heat Transfer with 17% FST, $M = 1.5$

This increased spread is associated with the mixing effect of the FST and is shown in Schauer and Bons (1994). The level of heat transfer is higher because the baseline from Fig. 3 is higher but the percent reduction in heat transfer has improved as FST has increased. Figure 7. shows the same data, again reduced with the addition of effectiveness data both published, and unpublished, from Bons et al. (1994). This heat transfer coefficient based on temperature difference from adiabatic wall conditions now shows a desirable lack of dependence on z at high levels of FST as does Fig. 6.

In a range of $0 < x/d < 30$ the heat transfer was less for the $M = 0.7$ blowing ratio. For the $Tu = 1\%$ case the $M = 0.7$ blowing ratio produced the strongest axial vortices according to the analysis and consequently poorer results at x/d values larger than 30. The mixing in both the higher FST cases was enough that little effect of blowing ratio could be observed for x/d values greater than 30. Figures 5 and 7 show only a small effect of either M or FST level, particularly on the film cooling hole centerline.




Figure 7a. Adiabatic Wall Heat Transfer with 17% FST, $M = 0.7$




Figure 7b. Adiabatic Wall Heat Transfer with 17% FST, $M = 1.5$

The analytical predictions are compared to the low FST heat transfer data in Figure 8. The magnitude of the change from the no film cooling case is predicted correctly for the $M = 0.7$ blowing. The prediction is nearly within experimental uncertainty at $M = 1.0$ and also at $M = 1.5$ for x/d values less than 45.




Figure 8a. Comparison of Analysis Data at 1% FST, $M = 0.7$




Figure 8b. Comparison of Analysis Data at 1% FST, $M = 1.0$

The analytical model over predicts the heat transfer augmentation at larger x/d 's for $M = 1.5$. The prediction at $M = 1.5$ could be improved if the vortex decay rate was changed in Eq. (11).

The blips in the analytical results are because the deviation from the standard flat plate found analytically in Eq. (13) were applied to the no film cooling data rather than results derived from Kays and Crawford (1980) Eq. (12-26). As seen in Fig. 3 the no film cooling data differs by only a few percent from the Kays and Crawford (1980) equation for this case of low FST.

The blips in the data at x/d of 50 and 74 are the result of two thermocouples partially detached from the heated film surface and are bad data.

CONCLUSIONS

1. Film cooling with aligned holes is only detrimental at low levels of FST. The axial vortices generated augment the heat transfer more than the shielding effects reduce it. Designers of film cooling configurations must be careful using data generated at low FST levels since mixing will be minimal and the potential for missing the effects seen in an actual high FST application are significant.
2. The undesirable heat transfer augmentation at low levels of FST is consistent with the predictions of the effects of an axial vortex generated by the whirling of the main stream flow under the film cooling jets.
3. Heat transfer between the free stream and the wall with film cooling will be minimized at an optimum level of FST. Increasing FST has two effects. The first tends to reduce heat transfer because of the increased mixing. The second tends to increase heat transfer because of the increases in the base line flat plate heat transfer as shown in Fig. 3.
4. With FST at 17%, the heat transfer coefficient on either a $T_w - T_\infty$ basis or $T_w - T_{aw}$ basis is reduced about 20% for x/d greater than 20.

5. Aligned film cooling holes can produce heat transfer uniform in the transverse direction at all but very low values of FST for distances from the holes of larger than about twenty film cooling hole diameters downstream.

REFERENCES

- Bons, J.P., MacArthur, C.D., and Rivir, R.B., 1994 The effects of High Freestream Turbulence on Film Cooling Effectiveness, ASME 94-GT-51.
- Kays, W.M. and Crawford, M.E., Convective Heat and Mass Transfer, 2nd Ed., 1980, McGraw-Hill, New York, NY.
- Jones, T.V., and Forth C.J.P., 1986 The Scaling of Film Cooling: Theoretical and Experimental Results, Conv. Ht. Tr. and Film Cooling in Turbomach., Von Karman Institute,
- Schauer, J.J., and Bons, J.P., 1994 Film Cooling Jet Mixing with Free Stream Turbulence, Inter Sym on Turbulence, Heat and Mass Transfer, Lisbon, Portugal, Aug. 9-12, p. P.I.3.
- Shapiro, A.H., 1953, The Dynamics and Thermodynamics of Compressible Fluid Flow, Vol.I, Roland Press, New York, NY.